

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date 21-6-23

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency- Welspun Krishna Industries
 Village - Azampur Husainpur Block- Sikandrabad
 District- Bulandshahr Logging Depth- 140 mt
 Drilling Depth- 140 mt Water Level- 9 mt

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 18	Sandy clay	
3	18 - 32	clay	
4	32 - 54	Medium Sand	Medium
5	54 - 60	clay	
6	60 - 66	Medium Sand	Medium
7	66 - 118	clay	
8	118 - 124	Sandy clay	
9	124 - 140	clay	
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

Singh
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.