

REPORT ON GEO-PHYSICAL ELECTRICAL  
LOGGING OF BOREHOLE

at  
Village: Sherpur Luhara  
Chhaprauli, Baghpat, Uttar Pradesh

For  
M/s. LC Infra Projects Private Limited.  
Ahmedabad.

*Conducted by*



**GLOBAL GROUND WATER CONSULTANTS**  
(Consulting Geologists & Geophysicists)  
84- III Floor, Humayun pur, Safdarjung Enclave, New Delhi - 110 029  
Phone: **9818-888824; 9818-007038.**

Date: 21<sup>st</sup> April 2023

## REPORT ON GEO-PHYSICAL RESISTIVITY LOGGING OF BOREHOLE

At

**Village: Sherpur Luhara**  
Chhaprauli, Baghpat, Uttar Pradesh

**Introduction:**

A deep borehole 142 (466 Feet) was drilled *M/s. LC Infra Projects Limited, Ahmedabad*, On the request of *M/s. LC Infra Projects Limited, Ahmedabad*, GGWC conducted a Geophysical Resistivity logging in the above borehole using IGIS's Logger dated 21<sup>st</sup> April 2023

Based on the interpretation of the Logging, the following litho logy has been inferred which tallies fairly well with the well-site litho-log based on mud-wash samples.

<i>Depth in m</i>	<i>Expected Litholog</i>	<i>Expected Quality</i>
0 - 3	Surface Soil	
3 - 11	Clay	
11 - 25*	Medium sand	Good
25 - 43*	Medium to fine sand	Good
43 - 68*	Medium sand	Good
68 - 76	Sandy clay	
76 - 89*	Medium sand	Good
89 - 100	Sandy clay	
100 - 107*	Very fine sand	Good
107 - 111	Sandy clay	
111 - 117*	Medium sand	Good
117 - 124	Sandy clay	
124 - 142	Clay kankar	

*Conclusions and Recommendations:*

1. The litholog inferred broadly tallies with that of the well-site litholog.
2. The zones marked with asterisk (\*) appear to be Aquifer Zones for possible development of tubewell.
3. As per thickness of the Aquifer the expected discharge is 50,000 LPH to 60,000 LPH.
4. Water Level is 23 m below ground level.
5. The Quality of water is good. However, it is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
6. The shallow aquifers are also recommended for development to get good quantity of water.
7. *All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.*

*for Global Groundwater Consultants*



*Chief Executive*

### SP and Resistivity Curves






Photo of the Site at the time of Logging