



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
 Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date.. 08-10-2023

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency..... Wellspan Krishna Industries
 Village..... Tamilpur Budhera..... Block..... Khwaja
 District..... Bulandshahr Logging Depth..... 137 mtr.
 Drilling Depth..... 140 mtr. Water Level..... 19 mtr.

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 14	Dry Sand	
3	14 - 20	clay KanKar	
4	20 - 26	Fine to med. Sand	
5	26 - 31	clay KanKar	
6	31 - 36	Fine to med. Sand	medium
7	36 - 40	clay KanKar	
8	40 - 45*	Fine to med. Sand	medium
9	45 - 50	clay KanKar	
10	50 - 67*	medium Sand str.	medium
11	67 - 86	clay KanKar	
12	86 - 92*	Fine to med. Sand str.	medium
13	92 - 108	clay KanKar	
14	108 - 111	Fine Sand	medium
15	111 - 137	clay KanKar	
16			
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

[Signature]
 Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.