

GSTIN : 09AEOPG8965L2ZJ



# GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc\_agra@yahoo.com

Ref No.....


Date...19.4.23.....

## GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

### DETAIL OF WATER BEARING ZONES

Name Of Agency... welspun Teeva Geo Centre  
 Village - Bagwale Block- Agota  
 District- Bulandshahr Logging Depth- 145mts  
 Drilling Depth- 145mts Water Level- 14mts

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface Soil	
2	5-13	clay	
3	13-21	Medium Sand	Medium
4	21-25	clay loam	
5	25-37	Medium Sand	Medium
6	37-45	clay loam	
7	45-51	Medium Sand	Medium
8	51-60	clay loam	
9	60-80	Medium Sand	Medium
10	80-92	clay loam	
11	92-130	Medium Sand	Medium
12	130-145	clay loam	
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

*Sanku*  
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,  
Well Construction of Tubewells, Ground Water Investigations