



# GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc\_agra@yahoo.com

Ref No. ....


Date: 11/02/2024

## GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

### DETAIL OF WATER BEARING ZONES

Name Of Agency- wellspan Krishna Industries  
 Village- Rajneri, Ind. Sarala Block- Amupshahr  
 District- Balanashahr Logging Depth- 140 mtr  
 Drilling Depth- 140 mtr Water Level- 9 mtr

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 10	clay Konkara	
3	10 - 19	Fine to med. Sand	med. to Good
4	19 - 25	clay Konkara	
5	25 - 32	Fine to med. Sand	med. to Good
6	32 - 38	clay Konkara	
7	38 - 51	medium Sand	med. to Good
8	51 - 55	clay Konkara	
9	55 - 60*	medium Sand	med. to Good
10	60 - 65	clay Konkara	
11	65 - 71*	medium Sand	med. to Good
12	71 - 91	clay Konkara	
13	91 - 112*	medium Sand	med. to Good
14	112 - 116	clay Konkara	
15	116 - 123*	Fine to med. Sand	med. to Good
16	123 - 140	clay Konkara	
17			
18			
19			
20			
21			
22			
23			



\* Expected Water Bearing Zone

For Ground Water Survey Consultancy

*VK*

Geophysicist

### Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,  
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.