

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Ph : 0562 - 4058694 (M) 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

Ref No.....

Date 24.7.22

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency - Wood Hill Infrastructure and related client machinery store

Village - Kapur Block - Maleud

District - Saharanpur Logging Depth - 158 mts

Drilling Depth - 160 mts Water Level - 15 mts

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface soil	
2	5 - 12	clay kankar	
3	12 - 19	Sandy clay	
4	19 - 23	clay kankar	
5	23 - 40	fine to med sand	Good
6	40 - 73	medium sand	Good
7	73 - 80	kankar	
8	80 - 87	Medium Sand	Good
9	87 - 91	clay kankar	
10	91 - 99	Medium sand	Good
11	99 - 104	clay kankar	
12	104 - 107	Medium sand	Good
13	107 - 120	clay kankar	
14	120 - 125	Medium Sand	Good
15	125 - 134	clay kankar	
16	134 - 145	Med Sand & kankar	Good
17	145 - 158	clay kankar	
18			
19			



*Expected Water Bearing Zone

For Ground Water Survey Consultancy

Singh
Geophysicist

Specializations In