



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date..09-08-2023

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency..... wellspan Krishna Industries
 Village Bhaipura Block..... Bulandshahar
 District..... Bulandshahar Logging Depth..... 14mtr
 Drilling Depth..... 15mtr Water Level..... 12 mtr

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 10	Very Sand	
3	10 - 12	clay Kankar	
4	12 - 16	Fine Sand	
5	16 - 23	clay Kankar	
6	23 - 35	Fine to med. Sand	medium
7	35 - 40	clay Kankar	
8	40 - 43	Fine Sand	medium
9	43 - 59	clay Kankar	
10	59 - 65*	Fine to med. Sand	medium
11	65 - 80	clay Kankar	
12	80 - 111*	medium Sand	medium
13	111 - 129	clay Kankar	
14	129 - 135*	medium Sand	medium
15	135 - 140	clay Kankar	
16			
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

[Signature]

Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.