Contractor: M/S. L.C. Infra

**GLOBAL GROUND WATER CONSULTANTS**
84-III Floor, Humayunpur, Safdarjung Enclave, New Delhi - 110 029
Mobile : 9818 888 824, 9818 007 038
E-mail : srikanthchukka.c23@gamil.com, ravikanth44@yahoo.com

## GEOPHYSICAL ELECTRICAL LOGGING REPORT AT

Tubewell No. : .....  Date : 3.07.2022

Village : PICHOKRA

Block : BINAULI

District : Bagpat, U.P

| Depth in Metres | Expected Litholog | Expected Water Quality |
|---|---|---|
| 0 - 3m | Surface Soil | |
| 3 - 11 | clay | |
| 11 - 19 | Fine Sand | |
| 19 - 26 | Sandy clay | |
| 26 - 56 | Fine Sand | Good |
| 56 - 61 | Sandy clay | |
| 61 - 86 | medium Sand | Good |
| 86 - 98 | clay kankar | |
| 98 - 105 | medium Sand | Good |
| 105 - 118 | Sandy clay | |
| 118 - 130 | clay kankar | |
| 130 - 137 | medium Sand | Good |

For Global Groundwater Consultants

M. RAVI (GEOLOGIST)
3/7/2022

EXPECTED WATER ZONE

WATER LEVEL : .....19..... METRES

Consulting Geologists, Geophysists & Ground Water Specialists

**Fig No:- 06- Logging Report**