

GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL ELECTROLOGGING REPORT

Ref No:-A- 229

Date:- 13-04-2023

NAME OF SITE

GRAM PANCHAYAT- Harsu Nagla

BLOCK- Milak

DISTT- Rampur

NAME OF AGENCY

M/s PNC-SPML-JV

Moradabad

22, CAMAC STREET, BLOCK-A, 3rd FLOOR, KOLKATA-700016



GROUND WATER SURVEY CONSULTANCY


Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO : 9001 : 2015

Ground Water Survey Consultancy



REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- HARSU NAGLA, BLOCK- MILAK, DISTT- RAMPUR
UNDER
JAL JIVAN MISSION

Introduction :

A Deep bore hole was drilled 120 mtrs. depth. and Logged depth 120 mtrs. at above site. Was drilled by M/S PNC-SPML-JV, Moradabad.

On the request of M/S PNC-SPML-JV, Moradabad. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 13.April.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 14	9	Fine sand	
3.	14 - 19	5	Clay kankar	
4.	19 - 35	16	Medium sand	Med to Good
5.	35 - 38	3	Clay kankar	
6.	38 - 45	7	Medium sand	Med to Good
7.	45 - 47	2	Clay kankar	
8.	47 - 52*	5	Medium sand	Med to Good
9.	52 - 57	5	Clay kankar	
10.	57 - 65*	8	Medium sand	Med to Good
11.	65 - 70	5	Clay kankar	
12.	70 - 81*	11	Medium sand	Med to Good
13.	81 - 86	5	Clay kankar	
14.	86 - 100*	14	Medium sand	Med to Good
15.	100 - 105	5	Clay kankar	
16.	105 - 118*	13	Medium sand	Med to Good
17.	118 - 120	2	Clay	

Ground Water Survey Consultancy



Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium to Good.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist



Ground Water Survey Consultancy

No. 1
 N/S (K)
 N/S (M)
 LAT
 Project Name:
 Agency for Survey, Design
 and Construction
 of Water
 Supply Schemes in
 India
 Project No. 1
 Survey No. 1
 Date: 11/11/2011
 Page 5 No.
 S/S: 11/11/2011-22
 Scale: 1:1000
 S (m V)
 Project Name:
 GROUND WATER
 SURVEY
 CONSULTANCY
 - AGRA INDIA

