



LOGGING REPORT				
Sl N	Depth Range	Thickness(M)	Remarks	
1	18 - 22	4	Good	
2	34 - 47	13	Good	
3	59 - 66	7	Good	
4	75 - 79	4	Good	
5	80 - 92	12	Good	
6	96 - 100	4	Good	
7	110 - 114	4	Good	
8	124 - 128	4	Good	
9	134 - 141	7	Good	
10	174 - 181	7	Good	

1	District:-	MAHARAJGANJ
2	Block:-	NAUTANWA
3	Scheme Name:-	SINGHORWA & ARAJI MAHUWA
4	Date of Logging:-	15.01.2024
5	Date of Lowering:-	24.01.2024
6	Size of Assembly:-	300X150
7	Size of Bore:-	600X500
8	Required Discharged:-	650
9	Logging Depth:-	214.00 M
10	Total Assembly Lowered :-	187.06 M
11	Housing Pipe:-	36.00 M
12	Plain Pipe	126.86 M
13	Slotted Pipe	24.00 M
14	Logging By:-	GEO INSTRUMENTS & TECHNIC'S

CLIENT:	STATE WATER SANITATION MISSION (NAMAMI GANGE & RURAL WATER SUPPLY SCHEME DEPARTMENT) GOVERNMENT OF UTTAR PRADESH		
PROJECT:-	MAHARAJGANJ NEW VILLAGE WATER SUPPLY SCHEME		
CONTRACTOR/FIRM :-	RITHWIK KOYA JV		
DRWN	NAME	SIGN	TITLE:
DSGN:-			ACTUAL TUBEWELL ASSEMBLE LOWERING DRAWING
CHKD :-			GP: SINGHORWA & ARAJI MAHUWA WATER SUPPLY SCHEME
DAPP :-			
DATE :-	-----		SHEET NO.
			1 OF 1
			SIZE A4
DRAWING NO.------			

UM=III

GP: - Sinhora

Block: - Nautanwa, Maharajganj

Logging Date: - 15-01-2024

Drilling Depth: - 220, 600x500

Logging Depth: - 214, 300x150

LPM: - 650, 300x150

Slotted: - 24 mtr

Date: - 23-01-2024

Logging Report

- ① 18 - 22 = 04
- ② 34 - 47 = 13
- ③ 59 - 66 = 07 = 06
- ④ 75 - 79 = 04
- ⑤ 88 - 92 = 04 = 03
- ⑥ 96 - 100 = 04
- ⑦ 110 - 114 = 04 = 03
- ⑧ 124 - 128 = 04
- ⑨ 134 - 141 = 07 = 06
- ⑩ 174 - 181 = 07 = 06

34	6.04	
33	6.05	
32	6.06	36.33
31	6.06	
30	6.06	
29	6.06	35.83
	0.2	36.03
28	6.03	
27	6.05	= 23.47
26	6.03	
25	5.36	59.50
24	6.03	6.03 65.53
23	6.02	
22	6.04	= 22.97
21	6.04	
20	4.87	88.50
19		3.00
18	6.05	91.50
17	6.04	= 19.09
16	4.00	
15	3.00	110.59
14	6.03	3.00 113.59
13	6.04	
12	6.05	= 20.91
11	6.04	
10	2.78	134.50
9	6.03	6.03 140.53
8	6.02	
7	6.05	
6	6.04	= 33.97
5	6.04	
4	6.02	
3	3.80	174.50
2	6.04	6.04 180.54
1	6.02	186.56
		+ 0.5

total Logging = 186.56 + 0.5 = 187.06
187.06 mtr

187.06