



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....

Date... 23-09-2023

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency..... wellspan..... Krishna Industries.....
 Village..... Mohammadpur Kala..... Block..... Sikondrabad.....
 District..... Bulandshahr..... Logging Depth..... 135 mtr.....
 Drilling Depth..... 140 mtr..... Water Level..... 3 mtr.....

| S.No | Depth in Mtr. | Lithology | Expected Water Quality |
|------|---------------|--------------------|------------------------|
| 1 | 0 - 5 | Surface Soil | |
| 2 | 5 - 15 | clay KanKar | |
| 3 | 15 - 18 | Fine Sand | |
| 4 | 18 - 25 | clay KanKar | |
| 5 | 25 - 33 | medium Sand | Good |
| 6 | 33 - 41 | clay KanKar | |
| 7 | 41 - 67* | medium Sand & Kan. | Good |
| 8 | 67 - 80 | clay KanKar | |
| 9 | 80 - 85 | Fine Sand | marginally saline |
| 10 | 85 - 102 | clay KanKar | |
| 11 | 102 - 105 | very Fine Sand | marginally saline |
| 12 | 105 - 110 | clay KanKar | |
| 13 | 110 - 117 | Fine Sand & KanKar | marginally saline |
| 14 | 117 - 135 | clay KanKar | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |
| 21 | | | |
| 22 | | | |
| 23 | | | |

* Expected Water Bearing Zone

For Ground Water Survey Consultancy

Vishal
 Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.