

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS


112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
 Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No..... Date.. 06-07-2023

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT DETAIL OF WATER BEARING ZONES

Name Of Agency..... Samira Shadab Infrastructure..... Shadab Rashid
 Village..... Patka, Agra..... Block..... Dika
 District..... Bulandshahr..... Logging Depth..... 15 mtr
 Drilling Depth..... 1.50 mtr..... Water Level..... 11 mtr

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 10	Day Sand	
3	10 - 20	Fine Sand	
4	20 - 26	clay Konkaz	
5	26 - 35	medium Sand	medium
6	35 - 41	clay Konkaz	
7	41 - 50*	medium Sand	medium
8	50 - 56	clay Konkaz	
9	56 - 66*	medium Sand	medium
10	66 - 71	clay Konkaz	
11	71 - 85*	medium Sand	medium
12	85 - 103	clay Konkaz	
13	103 - 113*	medium Sand	medium
14	113 - 120	clay Konkaz	
15	120 - 132*	Fine to med. Sand	medium
16	132 - 150	clay Konkaz	
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

V. P. Singh
 Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.