

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com


Ref No.

Date 3-6-22

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT DETAIL OF WATER BEARING ZONES

Name Of Agency- Wood Hill Infrastructure Chand machinery store
Village- SP wazirpur Block- Gangoh
District- Saharanpur Logging Depth- 162mts
Drilling Depth- 172mts Water Level- 26mts

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface Soil	
2	5-20	Dry Sand	
3	20-25	chy kankar	
4	25-30	fine sand	
5	30-40	chy kankar	
6	40-55'	Medium Sand	Sand
7	55-60	chy kankar	
8	60-70'	Medium Sand	Sand
9	70-74	chy kankar	
10	74-76	fine & Med Sand	Sand
11	76-90	chy kankar	
12	90-92'	fine & Med Sand	Sand
13	92-97	chy kankar	
14	97-105'	Medium sand	Sand
15	105-111	chy kankar	
16	111-136"	Medium Sand	Sand
17	136-158	chy kankar	
18	158-162	Sandy chy	
19	162-168	chy kankar	



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

S. Singh
Geophysicist

Specializations In

Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,