

GSTIN : 09AEOPG8885L2Z1



# GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS


112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006  
 Mob : 9761163000, 9794625420, Email : gwsc\_agra@yahoo.com

Ref No. .... Date: 14-05-2023

## GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT DETAIL OF WATER BEARING ZONES

Name Of Agency: Wellspan Pvt. Ltd. Yash Enterprises  
 Village: Sarbani Block: Agra  
 District: Bulandshahr Logging Depth: 150m  
 Drilling Depth: 150m Water Level: 6m

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface Soil	
2	5-8	clay Kankar	
3	8-18	Fine Sand	
4	18-22	clay Kankar	
5	22-33	Fine to medium Sand	medium
6	33-37	clay Kankar	
7	37-47	medium Sand	medium
8	47-66	clay Kankar	
9	66-78*	medium Sand	medium
10	78-85	clay Kankar	
11	85-93*	medium Sand	medium
12	93-105	clay Kankar	
13	105-116*	medium Sand	medium
14	116-131	clay Kankar	
15	131-140*	medium Sand	medium
16	140-150	clay Kankar	
17			
18			
19			
20			
21			
22			
23			



\* Expected Water Bearing Zone For Ground Water Survey Consultancy

*V. S. Jais*  
 Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,  
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.