



Contract No: m/s. L.C. Infra



GLOBAL GROUND WATER CONSULTANTS

84-III Floor, Humayunpur, Safdarjung Enclave, New Delhi - 110 029
 Mobile : 9818 888 824, 9818 007 038
 E-mail : srikanthchukka.c23@gamil.com, ravikanth44@yahoo.com

GEOPHYSICAL ELECTRICAL LOGGING REPORT AT

Tubewell No. :


Date : 14.8.2022

Village : MUSA FARUJI - KANWARA

Block : Binoli

District : Baghpat, U.P.

Depth in Metres	Expected Litholog	Expected Water Quality
0-3m	Surface Soil	
3-21	Sandy clay	
21-28	clay	
28-32	Sandy clay	
32-46	medium sand	Good
46-51	Sandy clay	
51-69	medium sand	Good
69-73	Sandy clay	
73-89	medium sand	Good
89-93	clay	
93-104	Fine sand	Good
104-117	medium sand	Good
117-148	clay kankar	
148-151	Fine sand	Good
151-160	clay kankar.	



⊗ EXPECTED WATER ZONE

▽ WATER LEVEL : 2.2 METRES

For Global Groundwater Consultants

(Signature)
 M. RAJ KANISH
 14/8/2022

Consulting Geologists, Geophysicists & Ground Water Specialists

Fig No 06 Water logging Report