

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date 21.4.23

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency..... Welspun Krishna Industries
 Village..... Tayebpur Block..... Shikerpur
 District..... Maharajpur Logging Depth..... 150 mtr
 Drilling Depth..... 150 mtr Water Level..... 20 mtr

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface Soil	
2	5-20	Dry Sand clay	
3	20-35	Medium Sand	Medium
4	35-45	clay loam	
5	45-55	Medium Sand	Medium
6	55-60	Clay loam	
7	60-69	Medium Sand	Medium
8	69-77	clay loam	
9	77-82	fine to med sand	Medium
10	82-98	clay loam	
11	98-108	fine + med sand	Medium
12	108-125	clay loam	
13	125-133	fine + med sand	Medium
14	133-138	clay loam	
15	138-148	fine + med sand	Medium
16	148-150	clay	
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

Suresh
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.