

GSTIN : 09AEOGP8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....

Date 30.7.23

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES


Name Of Agency - Welspun Enterprises Infrastructure Services Industries

Village - Bahorabasi Sherpur Block - Sahasrabudh Khurja

District - Bulandshahr Logging Depth - 140 mt

Drilling Depth - 140 mt Water Level - 110 mt Aft

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface Soil	
2	5-10	Dry Sand	
3	10-36	clay loam	
4	36-60	medium sand	medium
5	60-65	clayey	
6	65-70	fine to med sand	medium
7	70-87	clay loam	
8	87-105	fine to med sand	medium
9	105-140	clayey	
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.