

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date 26/10/2023

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency- wellspan Krishna Industries
 Village - Harangarh Block- Khurja
 District- Bulandshahr Logging Depth- 140. meter
 Drilling Depth- 140. mtr. Water Level- 12. mtr.

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 10	clay Kanjar	
3	10 - 17	Fine Sand	
4	17 - 21	clay Kanjar	
5	21 - 28	Fine to med. Sand	medium
6	28 - 34	clay Kanjar	
7	34 - 47*	medium Sand	medium
8	47 - 55	clay Kanjar	
9	55 - 58	Fine Sand	medium
10	58 - 65	clay Kanjar	
11	65 - 73*	Fine to med. Sand & Kan.	medium
12	73 - 83	clay Kanjar	
13	83 - 95*	medium Sand	medium
14	95 - 114	clay Kanjar	
15	114 - 117	Fine Sand	medium
16	117 - 132	clay Kanjar	
17	132 - 135	Fine Sand	medium
18	135 - 140	clay Kanjar	
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

V/S
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.