



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date 27/04/2024

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency- wellspan Krishna Industries
 Village- Yunapur Block- Dampur
 District- Bulandshahr Logging Depth- 137 mtr
 Drilling Depth- 140 mtr Water Level- 13 mtr

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 10	Dry Sand	
3	10 - 26	Sandy clay	
4	26 - 30	Fine Sand	med. to Good
5	30 - 36	clay Konkarr	
6	36 - 40	Fine to med. Sand	med. to Good
7	40 - 52	clay Konkarr	
8	52 - 67*	medium Sand	med. to Good
9	67 - 78	clay Konkarr	
10	78 - 82	Fine Sand	med. to Good
11	82 - 86	clay Konkarr	
12	86 - 108*	medium Sand	med. to Good
13	108 - 124	clay Konkarr	
14	124 - 129*	Fine to med. Sand	med. to Good
15	129 - 137	clay Konkarr	
16			
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.