

# GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

## GEO-PHYSICAL WELL ELECTROLOGGING REPORT

Ref No:-B- 1299

Date:- 18-07-2023

### NAME OF SITE

GRAM PANCHAYAT- Ahamad Nagar

BLOCK- Milak

DISTT- Rampur

### NAME OF AGENCY

M/s NKG Infrastructure Limited  
Delhi



## GROUND WATER SURVEY CONSULTANCY

Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

(M) : 9412260823, 9794625420, 9761163000, Email : gwsc\_agra@yahoo.com

**ISO ; 9001 : 2015**

Ground Water Survey Consultancy



# REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- AHAMAD NAGAR, BLOCK- MILAK, DISTT- RAMPUR  
UNDER  
JAL JIVAN MISSION

## Introduction :

A Deep bore hole was drilled 140 mtrs. depth. and Logged depth 132 mtrs. at above site. Was drilled by M/s NKG Infrastructure Limited, Delhi.

On the request of M/s NKG Infrastructure Limited, Delhi. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 18.July.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 10	5	Clay kankar	
3.	10 - 15	5	Sandy clay	
4.	15 - 20	5	Clay kankar	
5.	20 - 25	5	Fine sand	Medium
6.	25 - 30	5	Clay kankar	
7.	30 - 36	6	Fine to Medium sand	Medium
8.	36 - 48	12	Clay kankar	
9.	48 - 53*	5	Medium sand	Medium
10.	53 - 60	7	Clay kankar	
11.	60 - 81*	21	Medium sand	Medium
12.	81 - 85	4	Clay kankar	
13.	85 - 95*	10	Medium sand & kankar	Medium
14.	95 - 100	5	Clay kankar	
15.	100 - 108*	8	Fine to Medium sand	Medium
16.	108 - 114	6	Clay kankar	
17.	114 - 121*	7	Fine to Medium sand	Medium
18.	121 - 125	4	Clay kankar	
19.	125 - 127	2	Fine sand	Medium
20.	127 - 132	5	Clay kankar	

Ground Water Survey Consultancy



**Conclusions and Recommendations :-**

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (\*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

**Geophysicist**



**Ground Water Survey Consultancy**

