

Project Name :

Implementation of various rural water supply project including O&M for 10 Year for Nirkhi village, Block-Amauli, District-Fatehpur of Pradesh Under Jal Jeevan Mission Phase-III

Actual Lowering Chart at Vill. Nirkhi 150*300

Discharge = 800 LPM

Gram Panchayat :

Nirkhi

Block :

Amauli

District :


Fatehpur

Sr No.		
1	TW Const. By	M/s PMPL-BRCCPL(JV)
2	Size of Borewell	150*300
3	Date of Logging	28.07.2023
4	Date of Lowering	07.08.2023

Abstract of Pipe				
Sr. No.	Description	UOM	Item	Qty
1	300 MM	MTR	PLAIN PIPE	66.04
2	150x300 MM	MTR	Reducer	0.20
3	150 MM	MTR	PLAIN PIPE	57.31
4	150 MM	MTR	SLOTTED PIPE	27.00
Total Length				150.55

Logging Report			
Sr. No.	Description	Thickness(M)	Quality of G.W
1	43-50	7	ALL GOOD
2	77-81	4	
3	87-97	10	
4	112-115	3	
5	123-130	7	
6	141-144	3	
7	151-154	3	
8	156-160	4	

Note :- All zones are intermixed with fine bands of kankar.



[Signature]
TP (ME) Engineer

[Signature]
Junior Engineer

[Signature]
Assistant Engineer

[Signature]
Executive Engineer

M/s Mahalaxmi Tube well



Rajnendra Nagar Pukhrayan Kanpur
9935299290 mahalaxmitubewell@gmail.com

Geophysical Well Logging Report

Ref No - 07/282

Date -29/07/2023

Site Location : - Nirkhi Amauli Fatehpur
District : - Fatehpur
Logged Depth : - 165 M BGL
Date of Logging : - 28/07/2023
Types of Log : - S.P& N16, N-64 LAT
Logger used : - IGIS
Name of Agency : - PMPL-BRCCPL (JV) FATEHPUR
Rm -17.5Ω Rw -18.Ωm

The following permeable granular zones have been deciphered with the help of Electrical Logger

Sr NO	Depth Range From M.B.G.L	Depth Range M.B.G.L.	Thickness Mtr.	Inferred Lithology	Quality of G.W.
01	43	50	07	Fine to medium Sand	Good
02	77	81	04		
03	87	97	10		
04	112	115	03		
05	123	130	07		
06	141	144	03		
07	151	154	03		
08	156	160	04		

Note- All zones are intermixed with fine bands of kankar.

P. Uma Maheshwara Rao,
M. Sc.

P Uma Maheshwara Rao
P. Uma Maheshwara Rao
Hydrologist



PMPL - BRCCPL (JV)



Survey, Design, Preparation of DPR, Construction, commissioning and O & M for 10 Years of various Rural Water Supply Projected in the state of Uttar Pradesh as per the request for Proposal for Division - Prayagraj

STATE WATER & SANITATION MISSION, UTTAR PRADESH

M/s MEDHAJ TECHNO CONCEPT PVT LTD

M/s PMPL - BRCCPL (JV) FATEHPUR

REQUEST FOR INSPECTION / APPROVAL

RFI No :-

Date: 07/08/2023

Drawing No:

Location: GP- Ninkhi

BLOCK- Amauli

Request for Inspection on

- | | | |
|--|--|--|
| <input type="checkbox"/> SBC | <input type="checkbox"/> Hydro Testing | <input type="checkbox"/> Road Restoration |
| <input type="checkbox"/> Procurement | <input type="checkbox"/> Form Work & Reinforcement Checking | <input type="checkbox"/> Electrical & Mechanical Works |
| <input type="checkbox"/> Tube Well Drilling | <input checked="" type="checkbox"/> Tube Well Lowering | <input type="checkbox"/> Cubes Testing |
| <input type="checkbox"/> Compressor OP Unit | <input type="checkbox"/> Electro Logging | <input type="checkbox"/> Boundary Wall Work |
| <input type="checkbox"/> Solar Work / Electrification Work | <input type="checkbox"/> Pipe Laying & Jointing, Backfilling | <input type="checkbox"/> Commissioning of Scheme |
| <input type="checkbox"/> Structural Concrete | <input type="checkbox"/> Other Misc works | |

Work Particulars

Chainage / Node No
Description of works

WORK- Tubewell lowering work

GRAM PANCHYAT- Ninkhi

BLOCK- Amauli

Requested By

Received by

Name: *Om Prakash*

Signature: *Om*

Date: 06/08/2023

Name

Signature: *Prady Manoj*

Date

M/s MEDHAJ TECHNO CONCEPT PVT LTD

Comments (if any):-

Tick to Indicate

- Approval to Commerce Work.
- Remedial works required as above but no further approval required

For PMPL-BRCCPL (JV)

For T.P.I

For Jal Nigam

Signature

Signature

Signature

Name

Name: *Prady Manoj*

Name

Date

Date

Date





PMPL - BRCCPL (JV)



Name of Project	Survey, Design, Preparation of DPR, Construction, commissioning and O & M for 10 Years of various Rural Water Supply Projected in the state of Uttar Pradesh as per the request for Proposal for Division - Prayagraj
Name of Employer	STATE WATER & SANITATION MISSION, UTTAR PRADESH
Employer Representative (TPI/PMC)	M/s MEDHAJ TECHNO CONCEPT PVT LTD
Name of Contractor	M/s PMPL - BRCCPL (JV) FATEHPUR

REQUEST FOR INSPECTION / APPROVAL

RFI No.:-	Date: 25/07/2023
Drawing No.:-	Location: GP- Nirkhi BLOCK- Armauli
Request for Inspection on	

- | | | |
|--|--|--|
| <input type="checkbox"/> SBC | <input type="checkbox"/> Hydro Testing | <input type="checkbox"/> Road Restoration |
| <input type="checkbox"/> Procurement | <input type="checkbox"/> Form Work & Reinforcement Checking | <input type="checkbox"/> Electrical & Mechanical Works |
| <input checked="" type="checkbox"/> Tube Well Drilling | <input type="checkbox"/> Tube Well Lowering | <input type="checkbox"/> Cubes Testing |
| <input type="checkbox"/> Compressor OP Unit | <input type="checkbox"/> Electro Logging | <input type="checkbox"/> Boundary Wall Work |
| <input type="checkbox"/> Solar Work / Electrification Work | <input type="checkbox"/> Pipe Laying & Jointing, Backfilling | <input type="checkbox"/> Commissioning of Scheme |
| <input type="checkbox"/> Structural Concrete | <input type="checkbox"/> Other Misc works | |

Work Particulars Chainage / Node No Description of works	WORK- Tubewell Drilling work
	GRAM PANCHYAT- Nirkhi
	BLOCK- Armauli

Requested By	Received by
Name: <i>Sanjay Prakash</i>	M/s MEDHAJ TECHNO CONCEPT PVT LTD
Signature: <i>Sanjay</i>	Signature: <i>[Signature]</i>
Date: 24/07/2023	Date:

Comments (if any):-

Tick to Indicate

- Approval to Commerce Work.
- Remedial works required as above but no further approval required

For PMPL-BRCCPL (JV)	For T.P.I	For Jal Nigam
Signature	Signature	Signature
Name	Name	Name
Date	Date	Date



[Signature]