



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date 05-09-2023

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency- Well Span Krishna Industries
 Village - Harachana Block- Gaulauti
 District- Bulandshahr Logging Depth- 140 mtr.
 Drilling Depth- 140 mtr. Water Level- 15 mtr.

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 14	clay KanKar	
3	14 - 20	Fine Sand	
4	20 - 30	clay KanKar	
5	30 - 54*	medium Sand	medium
6	54 - 60	KanKar	
7	60 - 71*	medium Sand	medium
8	71 - 80	clay KanKar	
9	80 - 96*	medium Sand	medium
10	96 - 104	clay KanKar	
11	104 - 120*	medium Sand	medium
12	120 - 140	clay KanKar	
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

V. S. P. S.
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.