



# GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9781163000, 9704625420, Email : gwsc\_agra@yahoo.com

Ref No. ....

Date 24-05-2029

## GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

### DETAIL OF WATER BEARING ZONES

Name Of Agency - Well Spoun - Yadu Enterprises  
 Village - Sinhali Shaya Block - Jahangirabad  
 District - Bulandshahr Logging Depth - 107 mtr.  
 Drilling Depth - 110 mtr. Water Level - 12 mtr.

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 11	Dry Sand	
3	11 - 15	clay Kankar	
4	15 - 20	Fine Sand	
5	20 - 25	clay Kankar	
6	25 - 35	Fine to med. Sand	Good
7	35 - 40	clay Kankar	
8	40 - 60*	Fine to med. Sand	Good
9	60 - 65	clay Kankar	
10	65 - 75*	Fine to med. Sand	Good
11	75 - 87	clay Kankar	
12	87 - 101*	Fine to med. Sand	Good
13	101 - 107	clay Kankar	
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			

\* Expected Water Bearing Zone

For Ground Water Survey Consultancy

*Vign*  
 Geophysicist

### Specializations in

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,  
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.