



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date 18-09-2023

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency- wellspour Krishna Industries
 Village - Madhapur Block- Khurja
 District- Bulandshahr Logging Depth- 134 mtr.
 Drilling Depth- 140 mtr. Water Level- 12 mtr.

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 10	Dry Sand	
3	10 - 15	Fine Sand	
4	15 - 25	clay Konkara	
5	25 - 30	Fine Sand	Good
6	30 - 35	clay Konkara	
7	35 - 43*	medium Sand	Good
8	43 - 45	clay Konkara	
9	45 - 58*	medium Sand	Good
10	58 - 65	clay Konkara	
11	65 - 72*	Fine to med. Sand & Kon.	medium
12	72 - 100	clay Konkara	
13	100 - 105	Konkara	
14	105 - 110	clay Konkara	
15	110 - 115	Fine Sand & Konkara	medium
16	115 - 134	clay Konkara	
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

V. S. P.
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.