



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date.....17-10-2023.....

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency- Wells.poun. Krishna. Industries
 Village - Subara Block- Sihandrabad
 District- Bulandshahr Logging Depth- 140mtr.
 Drilling Depth- 140mtr. Water Level- 3mtr.

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 20	clay Kankar	
3	20 - 30	medium Sand	Good
4	30 - 34	clay Kankar	
5	34 - 36	Fine Sand	Good
6	36 - 41	clay Kankar	
7	41 - 48*	medium Sand	Good
8	48 - 58	clay Kankar	
9	58 - 61	Fine Sand	marginally Saline
10	61 - 70	clay Kankar	
11	70 - 76	Fine Sand	marginally Saline
12	76 - 140	clay Kankar	
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

V/S
50/10
 Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.