



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
 Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date 25-05-2023

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency- Well Spun Krishna Industries
 Village- Satvai Block- Jahangirabad
 District- Bulandshahr Logging Depth- 125 mtr.
 Drilling Depth- 140 mtr. Water Level- 12 mtr.

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 10	Dry Sand	
3	10 - 20	clay Kankar	
4	20 - 37	Fine to med. Sand	Good
5	37 - 51	clay Kankar	
6	51 - 72*	medium Sand	Good
7	72 - 78	clay Kankar	
8	78 - 90*	Fine to med. Sand	Good
9	90 - 102	clay Kankar	
10	102 - 115*	medium Sand	Good
11	115 - 125	clay Kankar	
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

Utsav
 Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Decharge Well, Rectification of Tubewell, etc.