

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date 5.4.24

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONNES

Name Of Agency- wells poun krishna Industries
 Village - usmanpur Block- khurja
 District- Bulandshahr Logging Depth- 140 mtr
 Drilling Depth- 140 mtr Water Level- 11 mtr. Atp.

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 13	clay loam	
3	13 - 15	Sandy clay	
4	15 - 19	clay loam	
5	19 - 23	Fine Sand	Medium
6	23 - 27	clay loam	
7	27 - 30	Fine Sand	Medium
8	30 - 33	clay loam	
9	33 - 36	Fine + Med Sand	Medium
10	36 - 50	clay loam	
11	50 - 64	Medium Sand	Medium
12	64 - 66	clay loam	
13	66 - 78	Fine + Med Sand	Medium
14	78 - 90	clay loam	
15	90 - 94	Sandy clay	
16	94 - 109	clay loam	
17	109 - 113	Fine + Med Sand	Med + Marg. Salin
18	113 - 117	clay loam	
19	117 - 122	Fine + Med Sand	Med + Marg. Salin
20	122 - 130	clay loam	
21	130 - 137	Fine + Med Sand	Med + Marg. Salin
22	137 - 140	clay loam	
23			



*Expected Water Bearing Zone

For Ground Water Survey Consultancy

S. Singh
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.