



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....

Date..30/12/2023.....

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency.....wells pour.....Krishna Industries.....
 Village.....Raywara.....Block.....Lakhwati.....
 District.....Bulandshahr.....Logging Depth.....140 mtr.....
 Drilling Depth.....140 mtr.....Water Level.....11.2 mtr.....

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 12	clay Konkaz	
3	12 - 36	medium Sand	med. to Good
4	36 - 46	clay Konkaz	
5	46 - 56*	medium Sand	med. to Good
6	56 - 60	clay Konkaz	
7	60 - 70*	Fine to med. Sand & Kon.	med. to Good
8	70 - 80	clay Konkaz	
9	80 - 89*	medium Sand	med. to Good
10	89 - 104	clay Konkaz	
11	104 - 108*	Fine to med. sand	med. to Good
12	108 - 111	Konkaz	
13	111 - 117*	Fine to med. Sand	med. to Good
14	117 - 124	clay Konkaz	
15	124 - 130*	Fine to med. Sand & Kon.	med. to Good
16	130 - 140	clay Konkaz	
17			
18			
19			
20			
21			
22			
23			

* Expected Water Bearing Zone

For Ground Water Survey Consultancy

V. P. S.
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.