



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No.....


Date..08-10-2023

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency-.....wellspan..... Krishna Industries.....
 Village -.....Khaleiya Choharpur..... Block-.....Kbuzga.....
 District-.....Bulandshahr..... Logging Depth-.....140 mtr.....
 Drilling Depth-.....140 mtr..... Water Level-.....9 mtr.....

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 12	clay Konkaz	
3	12 - 17	Fine Sand	
4	17 - 22	clay Konkaz	
5	22 - 27	Fine to med. sand	med. to good
6	27 - 40	clay Konkaz	
7	40 - 61*	medium sand	med. to good
8	61 - 111	clay Konkaz	
9	111 - 114	Fine Sand	marginally saline
10	114 - 140	clay Konkaz	
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

VIC
PH
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.