

GROUND WATER SURVEY CONSULTANCY
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

**GEO-PHYSICAL WELL
ELECTOLOGGING REPORT**

Ref No:-A-1859

Date:- 12-10-2023

NAME OF SITE

GRAM PANCHAYAT- Bari Samaspur BLOCK- Salarpur DISTT- Badaun

NAME OF AGENCY

M/s PNC-SPML-JV
Badaun



GROUND WATER SURVEY CONSULTANCY

Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.
112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO ; 9001 : 2015

Ground Water Survey Consultancy
Agra



REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- BARI SAMASPUR, BLOCK- SALARPUR,
DISTT- BADAUN
UNDER
JAL JIVAN MISSION


Introduction :

A Deep bore hole was drilled 130 mtrs. depth. and Logged depth 130 mtrs. at above site. Was drilled by M/S PNC-SPML-JV, Badaun.

On the request of M/S PNC-SPML-JV, Badaun. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 12.Oct.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 20	15	Dry sand	
3.	20 - 29	9	Clay kankar	
4.	29 - 45	16	Medium sand	Medium
5.	45 - 51	6	Clay kankar	
6.	51 - 60*	9	Medium sand	Medium
7.	60 - 65	5	Clay kankar	
8.	65 - 79	14	Medium sand	Medium
9.	79 - 91	12	Clay kankar	
10.	91 - 101*	10	Medium sand	Medium
11.	101 - 109	8	Clay kankar	
12.	109 - 125*	16	Medium sand	Medium
13.	125 - 130	5	Clay kankar	



Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting starta chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tube well.
3. The Quality of water is expected Medium.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist


Ground Water Survey Consultancy

Sheet No. 1
 N16(SW)
 N64(SW)
 LAT

Logging Details
 Log No. 1
 Date 01/21/22
 Location

Sheet No. 1
 IGIS/01/21-22

Log No. 1
 Date 01/21/22
 Location

SP (m V)
 DIAPL-2
 Log No. 1
 Date 01/21/22
 Location

GROUND WATER SURVEY CONSULTANCY
 AGRA, UP India

