

GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL ELECTROLOGGING REPORT

Ref No:-B- 2377

Date:- 18-11-2023

NAME OF SITE

GRAM PANCHAYAT- Mevla Kalan

BLOCK- Swar

DISTT- Rampur

NAME OF AGENCY

M/s PNC-SPML-JV

Rampur

22, CAMAC STREET, BLOCK-A, 3rd FLOOR, KOLKATA-700016



GROUND WATER SURVEY CONSULTANCY

Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO : 9001 : 2015

Ground Water Survey Consultancy



REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- MEVLA KALAN, BLOCK- SWAR, DISTT- RAMPUR
UNDER
JAL JIVAN MISSION

Introduction :

A Deep bore hole was drilled 140 mtrs. depth. and Logged depth 140 mtrs. at above site. Was drilled by M/S PNC-SPML-JV, Rampur.

On the request of M/S PNC-SPML-JV, Rampur.. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 18.Nov.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 7	2	Fine sand	
3.	7 - 15	8	Clay kankar	
4.	15 - 25	10	Sand & kankar	
5.	25 - 57	32	Clay kankar	
6.	57 - 61*	4	Fine to Medium sand	Medium
7.	61 - 68	7	Clay kankar	
8.	68 - 73*	5	Medium sand	Medium
9.	73 - 78	5	Clay kankar	
10.	78 - 80*	2	Fine to Medium sand	Medium
11.	80 - 105	25	Clay kankar	
12.	105 - 117*	12	Medium sand	Medium
13.	117 - 130	13	Clay kankar	
14.	130 - 134*	4	Fine to Medium sand	Medium
15.	134 - 140	6	Clay kankar	



Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist

A handwritten signature in blue ink, appearing to be 'V.K. P.T.', is written over a circular blue ink stamp. The stamp contains some illegible text.

Ground Water Survey Consultancy

Rho a
 NI6 (SNT)
 NI6d(LN)
 LAT
 Logging Details
 Logging in meters on air block
 Power distribution
 UP LOGGING
 18 Nov 2023
 12.34
 User: gauravjain

Logger S No: IGIS/S01/10-11

Logger Model: SP (m V)
 DNP.L-2
 Logger Owned by:
 Ground Water
 Survey Consultancy
 Agre Up India
 India

