

GROUND WATER SURVEY CONSULTANCY
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

**GEO-PHYSICAL WELL
ELECTROLOGGING REPORT**

Ref No:-N-1452

Date:- 06-03-2023

NAME OF SITE

GRAM PANCHAYAT- Saindholi BLOCK- Milak DISTT- Rampur


NAME OF AGENCY

M/s PNC-SPML-JV
Moradabad
22, CAMAC STREET, BLOCK-A, 3rd FLOOR, KOLKATA-700016



GROUND WATER SURVEY CONSULTANCY

Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.
112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com



REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- SAINDHOLI, BLOCK- MILAK, DISTT- RAMPUR
UNDER
JAL JIVAN MISSION


Introduction :

A Deep bore hole was drilled 120 mtrs. depth. and Logged depth 120 mtrs. at above site. Was drilled by M/S PNC-SPML-JV, Moradabad.

On the request of M/S PNC-SPML-JV, Moradabad. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 06.Mar.2023.


Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 16	11	Clay kankar	
3.	16 - 41	25	Medium sand	Medium
4.	41 - 46	5	Clay kankar	
5.	46 - 84*	38	Medium sand	Medium
6.	84 - 90	6	Clay kankar	
7.	90 - 108*	18	Medium sand	Medium
8.	108 - 115	7	Clay kankar	
9.	115 - 120*	5	Fine to Medium sand	Medium



Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.



Ground Water Survey Consultancy

Rho ρ
 N 16(SN)
 N 64 (UN)
 LAT

Station: Jodhpur, Rajasthan, India
 No. of Channels: 20
 Log No: SP10000000
 Date: 11/11/11
 Time: 11:37
 Operator: V.K. Singh
 Well Name: Jodhpur-1
 UTM Zone: 48QUD

SP

