

GSTIN : 09AEOPG8865LZJ



# GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A Shree Nagar Colony Ferozabad Road Agra- 202005

Mob: 9781163000, 9794625420 Email: gwsc\_agra@yahoo.com

Ref No.

Date: 13/12/23

## GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

### DETAIL OF WATER BEARING ZONES

Name Of Agency: Nishvag Environment Care Developer  
 Village: Arshaya Sahaj Block: Barkheda  
 District: Dahad Logging Depth: 150 feet  
 Drilling Depth: 150 mtr Water Level: 6 mtr

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 25	fine sand	
3	25 - 32	clay loam	
4	32 - 45	Medium Sand	Sand
5	45 - 55	clay loam	
6	55 - 65	Medium Sand	Sand
7	65 - 66	clay loam	
8	66 - 79	Medium Sand	Sand
9	79 - 90	clay loam	
10	90 - 95	fine to med sand	Sand
11	95 - 100	clay loam	
12	100 - 110	Medium Sand	Sand
13	110 - 115	clay loam	
14	115 - 120	fine to med sand	Sand
15	120 - 130	clay loam	
16			
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

Geophysicist

Specializations in

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Borewells, Rehabilitation of Tubewells, Ground Water Investigation

