



# GROUND WATER SURVEY CONSULTANCY

**GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS**

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420, Email: gwsc\_agra@yahoo.com

Ref No.....

Date: 16/12/22

## GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

### DETAIL OF WATER BEARING ZONES

Name Of Agency: Vishvarej Environment Pvt Ltd Greta Developer  
 Village: Behn Phatma Block: Marori  
 District: Pilibhit Logging Depth: 150 mt  
 Drilling Depth: 150 mt Water Level: 9 mt

S.No	Depth In Mtr.	Lithology	Expected Water Quality
1	0-5	Surface Soil	
2	5-15	claystone	
3	15-50	Medium Sand	Med + Sand
4	50-60	claystone	
5	60-69	Medium Sand	Med + Sand
6	69-75	claystone	
7	75-95	Medium Sand	Med + Sand
8	95-100	claystone	
9	100-111	Sand & clay	Med + Sand
10	111-115	claystone	
11	115-124	Medium Sand	Med + Sand
12	124-128	claystone	
13	128-147	Medium Sand	Med + Sand
14	147-150	clay	
15			
16			
17			
18			
19			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

*S. Singh*  
Geophysicist

### Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.

