

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob. : 9761163000, 9794625420. Email : gwsc_agra@yahoo.com

Ref No.....

Date 8.12.22

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES


Name Of Agency- Yashveer Environment Pollution Control Development

Village - Kalya Block- MADRAS

District- Rajshahi Logging Depth- 150 mtr

Drilling Depth- 150 mtr Water Level- 7 mtr

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 34	Medium Sand	
3	34 - 40	Chy karka	
4	40 - 55	Medium Sand	Sand
5	55 - 62	Chy karka	
6	62 - 73	Medium Sand	Sand
7	73 - 82	Chy karka	
8	82 - 100	Medium Sand	Sand
9	100 - 105	Chy karka	
10	105 - 136	Medium Sand	Sand
11	136 - 145	Chy karka	
12	145 - 150	Medium Sand	Sand
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

Sasmita
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations


Lowering of Kallia 10% Scheme Distt- Pilibhit Block, Marauri
 TW Size - 200 x 150 mm Lowering Date - 07/12/22 Discharge - 500 lpm

200mm Housing pipe	150mm Plain pipe	150mm Slotted pipe
1- 6.02	1- 6.01 ✓	1- 6.01 ✓
2- 6.02	2- 6.02 ✓	2- 6.01 ✓
3- 6.02	3- 6.01 ✓	3- 6.05 ✓
4- 6.02	4- 6.03 ✓	4- 3.03 ✓
5- 6.03	5- 6.04 ✓	5- 3.03
6- 6.02	6- 6.06	<u>24.130</u>
7- 6.02	7- 6.07	
	8- 6.04	
	9- 6.01 ✓	
	10- 6.02	
	11- 6.01	
	12- 6.01 ✓	
	13- 6.01	
<u>42.15m</u>		

Logging Report 1st:

62m — 73m — M Sand — 6M
 82m — 100m — M Sand — 15m
 105m — 136m — M Sand

200mm Housing pipe	42.15m ✓
200x150mm Reducel	0.20m ✓
150mm Plain pipe	42.05m ✓
150mm Slotted pipe	21.10m
	<u>105.50m</u>
ACIL (-)	0.50m
	<u>105.00m</u>



[Handwritten signature]