



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
 Mob. : 9761163000, 9794625420, Email : gwsc_agra@yahoo.com

Ref No. B-191

Date 23-04-2023

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT

DETAIL OF WATER BEARING ZONES

Name Of Agency: C.V.E.P.L. Vishwarya Environment Res Ltd. Cruise
 Village: Ladpur Block: Lakshmi Kharia
 District: Relibhit Logging Depth: 147 mtr.
 Drilling Depth: 150 mtr. Water Level: 2 mtr.

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0-5	Surface Soil	
2	5-16	medium Sand	Good
3	16-20	clay Kankar	
4	20-23	Fine Sand	Good
5	23-27	clay Kankar	
6	27-30	Fine Sand	Good
7	30-35	clay Kankar	
8	35-41	Fine to med. Sand	Good
9	41-59*	clay Kankar	
10	59-64*	Fine to med. Sand	Good
11	64-70	clay Kankar	
12	70-73	Fine to med. Sand	Good
13	73-78	clay Kankar	
14	78-91*	medium Sand	Good
15	91-96	clay Kankar	
16	96-103*	medium Sand	Good
17	103-115	clay Kankar	
18	115-121	Sand & Kankar	Good
19	121-126	clay Kankar	
20	126-138*	medium Sand	Good
21	138-147	clay Kankar	
22			
23			



* Expected Water Bearing Zone

For Ground Water Survey Consultancy

[Signature]
 Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting, Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations.