

GSTIN : 09AEOPG8965L2ZJ



GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

Mob: 9761163000, 9794625420 Email: gwsc_agra@yahoo.com

Ref No

Date 4/12/22

GEOPHYSICAL ELECTRICAL WELL LOGGING FIELD REPORT DETAIL OF WATER BEARING ZONES

Name Of Agency- Vishwanath Environment Pvt Ltd
 Village - Agraya Block- Barkhoda
 District- Pilibhit Logging Depth- 150m
 Drilling Depth- 150m Water Level- 3m

S.No	Depth in Mtr.	Lithology	Expected Water Quality
1	0 - 5	Surface Soil	
2	5 - 13	clay loam	
3	15 - 66	Medium Sand	Medium
4	66 - 66	Clay loam	
5	66 - 81	Medium Sand	Medium
6	81 - 86	clay loam	
7	86 - 90	Medium Sand	Medium
8	90 - 100	clay loam	
9	100 - 136	Medium Sand	Medium
10	136 - 150	clay loam	
11			
12			
13			
14			
15			
16			
17			
18			
19			



Expected Water Bearing Zone

For Ground Water Survey Consultancy

[Signature]
Geophysicist

Specializations In

Electric Well Logging, Geophysical Survey, Resistivity Survey, Rainwater Harvesting,
 Construction of Recharge Well, Rectification of Tubewells, Ground Water Investigations

[Signature]


Lowering of Agyan WB scheme Dist - Pilibhit Block - Bareilly / 150/140
 T.W. Size: 300x200 mm² Lowering Date 04/12/22 discharge

300mm ² housing pipe	200mm ² Plain Pipe	200mm ² Slotted Pipe
1- 6.03	1- 5.86	1- 6.07
2- 6.02	2- 6.02	2- 6.03
3- 6.02	3- 6.05	3- 6.02
4- 6.02	4- 5.86	4- 6.00
5- 5.90	5- 6.01	5- 6.01
6- 6.00	6- 6.02	<u>30.09</u>
7- 6.02	7- 6.03	
<u>42.01</u>	8- 6.04	
	9- 6.03	
	10- 6.03	
	11- 6.02	
	12- 6.03 - RL	
	<u>71.98m</u>	

Logging Report As:-

- 66m — 81m — M. Sand
- 86m — 90m — M. Sand
- 100m — 136m — M. Sand

300mm ² housing pipe	42.01 M
300x200mm ² Reducer	0.25 M
200mm ² Plain Pipe	66.12 M
200mm ² Slotted Pipe	30.09 M
	<u>138.47 M</u>
Agd (-)	0.50 M
	<u>137.97 M</u>



[Handwritten signature]