

GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL ELECTROLOGGING REPORT

Ref No:-A-2186

Date:- 08-11-2023

NAME OF SITE

GRAM PANCHAYAT- Hathni Bhoot BLOCK- Samrer DISTT- Badaun

NAME OF AGENCY

M/s PNC-SPML-JV
Badaun



GROUND WATER SURVEY CONSULTANCY

Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO ; 9001 : 2015

Ground Water Survey Consultancy

Agra

REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- HATHNI BHOOT, BLOCK- SAMRER, DISTT- BADAUN
UNDER
JAL JIVAN MISSION

Introduction :

A Deep bore hole was drilled 140 mtrs. depth. and Logged depth 132 mtrs. at above site. Was drilled by M/S PNC-SPML-JV, Badaun.

On the request of M/S PNC-SPML-JV, Badaun. a Geophysical well Logging is conduct at above bore hole using IGIS Well Logger on 08.Nov.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 12	7	Fine to Medium sand	
3.	12 - 30	18	Clay kankar	
4.	30 - 37	7	Medium sand	Medium
5.	37 - 43	6	Clay kankar	
6.	43 - 47	4	Medium sand	Medium
7.	47 - 53	6	Clay kankar	
8.	53 - 75*	22	Medium sand	Medium
9.	75 - 83	8	Clay kankar	
10.	83 - 92*	9	Medium sand	Medium
11.	92 - 98	6	Clay kankar	
12.	98 - 102*	4	Medium sand	Medium
13.	102 - 106	4	Clay kankar	
14.	106 - 113*	7	Medium sand	Medium
15.	113 - 123	10	Clay kankar	
16.	123 - 128*	5	Medium sand	Medium
17.	128 - 132	4	Clay kankar	

Ground Water Survey Consultancy
Agra

UVC
JV

Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist



Ground Water Survey Consultancy

B Rio a

N16 (SN)
 N16 (LN)
 LAT

Logging Details
 Logging Co: Hapra Street
 No. 1, Borneo Dam, Jakarta
 JP: 022530012
 2230
 Utanra Bumi 040

Logger: S.M.C.
 Date: 2012/12/22

SP (m V)
 Logger Model: DMP12
 Logger Owned by:

GROUND WATER
 SURVEY
 CONSULTANCY
 AGRA, JIP, Indes

