

Lowering of Goochh W/S scheme Dist - Pilibhit Block - Lalorikhera | 150/140
 T.W Size - 300x200 mm lowering date 05/03/23 discharge - 750 lpm

300mm housing pipe	200mm plain pipe	200mm slotted pipe
1- 6.09	1- 6.01 ✓	1- (6.00)
2- 6.05	2- 6.00 ✓	2- 6.00 ✓
3- 6.10	3- 6.00 ✓	3- 6.01 ✓
4- 6.12	4- 6.00 ✓	4- 6.00 ✓
5- 6.08	5- 6.00 ✓	5- 6.01 ✓
6- 6.02	6- 5.98 ✓	
7- 5.88	7- 5.00 ✓	
	8- 6.00 ✓	
<u>42.34M</u>	9- 6.00 ✓	
	10- 5.87 ✓	
	11- 6.00 ✓	
	<u>65.86M</u>	

Logging Report As

70m — 81m — m-sand — 6+3
 103 — 116m — m-sand — 6+3
 120 — 129m — m-sand — 6.

Plain pipe	Slotted pipe
6.00 ✓	6.00 ✓
4.90mL	3.00mL
1.10mL	3.00mL
5.87 ✓	
1.50mL	
4.37mL	

300mm housing pipe	42.34M
300x200mm Reducer	0.25M
200mm plain pipe	65.86M
200mm slotted pipe	24.02M
	<u>132.47M</u>
AtL (-)	0.50M
	<u>131.97M</u>

