

GROUND WATER SURVEY CONSULTANCY  
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL  
ELECTROLOGGING REPORT

RefNo:- 153

Date:- 01-12-2021

NAME OF SITE

GRAM PANCHAYAT- Gola Raipur BLOCK- Sindholi DISTT- Shahjanhapur

NAME OF AGENCY

M/s NCC Ltd.  
Shahjanhapur




GROUND WATER SURVEY CONSULTANCY

Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

(M) : 9412260823, 9794625420, 9761163000, Email : gwsc\_agra@yahoo.com

**ISO ; 9001 : 2015**



# REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- GOLA RAIPUR, BLOCK- SINDHOLI,  
DISTT- SHAHAJANHAPUR  
UNDER  
JAL JIVAN MISSION

## Introduction :

A Deep bore hole was drilled 120 mtrs. depth. and Logged depth 119 mtrs. at above site. Was drilled by M/S NCC Ltd., Shahajanhapur.

On the request of M/S NCC Ltd., Shahajanhapur. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 01.Dec.2021.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major equifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 8	3	Fine sand	
3.	8 - 35	27	Clay kankar	
4.	35 - 50*	15	Medium sand	Good
5.	50 - 55	5	Clay kankar	
6.	55 - 60*	5	Medium sand	Good
7.	60 - 65	5	Clay kankar	
8.	65 - 72	7	Fine sand	Good
9.	72 - 95	23	Clay kankar	
10.	95 - 112*	17	Medium sand & Kankar	Good
11.	112 - 120	8	Clay kankar	

**Conclusions and Recommendations :-**

1. The Lithology broadly tallies with that of drill cutting starta chart.
2. The zones marked with asterisk (\*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Good.
4. Expected discharge is 800 to 1000 L.P.M.
5. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
6. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

**Geophysicist**



**Ground Water Survey Consultancy**

