GROUND WATER SURVEY CONSULT

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL ELECTOLOGGING REPORT

Ref No:- 258

Date: - 28-12-2021

NAME OF SITE

GRAM PANCHAYAT- Tihar Ajanpur BLOCK- Banda DISTT- Shahjanhapur

NAME OF AGENCY

M/s NCC Ltd. Shahjanhapur



GROUND WATER SURVEY CONSULTIVE

Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.
112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
(M): 9412260823, 9794625420, 9761163000, Email: gwsc_agra@yahoo.com

ISO; 9001: 2015

Ground Water Burvey Consultancy

REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- TIHAR AJANPUR, BLOCK- BANDA, DISTT- SHAHAJANHAPUR UNDER JAL JIVAN MISSION

Introduction:

A Deep bore hole was drilled 140 mtrs. depth. and Logged depth 140 mtrs. at above site. Was drilled by M/S NCC Ltd., Shahajanhapur.

On the request of M/S NCC Ltd., Shahajanhapur. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 28.Dec.2021.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major equifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Defth range(m)	Thickness(m)	Lithology	Expected Water Quality
1. mar pa ga	0 - 5	. 5	Surface soil	
2.	5 - 20	15	Clay kankar	
3.	20 - 26	6	Fine sand	
4.	26 - 32	6	Clay kankar	
5.	32 - 42	10	Medium sand	Good
6.	42 - 55	13	Clay kankar	
7.	55 - 76*	21	Medium sand	Good
8.	76 - 80	4	Clay kankar	
9.	80 - 90*	10	Medium sand	Good
10.	90 - 92	2	Clay	1000000
11.	92 - 100*	8	Medium sand	Good
12.	100 - 102	2	Clay kankar	
13.	102 - 112*	10	Fine to Medium sand	Good
14.	112 - 128	16	Fine sand	Good
15.	128 - 130	2	Clay kankar	
16.	130 - 136	6	Fine sand	Good
17.	136 - 140	4	Clay kankar	

Ground Water Survey Consultancy

Conclusions and Recommendations :-

- 1. The Lithology broadly tallies with that of drill cutting starta chart.
- 2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
- 3. The Quality of water is expected Good.
- 4. Expected discharge is 1200 to 1400 L.P.M.
- 5. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
- 6. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist

Ground Water Survey Consultancy



