

GROUND WATER SURVEY CONSULTANCY
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL
ELECTROLOGGING REPORT

Ref No:- 140

Date:- 19-11-2021

NAME OF SITE

VILLAGE- Bhundi

BLOCK- Khudaganj

DISTT- Shahjanhapur

NAME OF AGENCY

M/s NCC Ltd.
Shahjanhapur



GROUND WATER SURVEY CONSULTANCY

Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO ; 9001 : 2015

Ground Water Survey Consultancy
Agra

REPORT ON GEOPHYSICAL WELL LOGGING AT

VILLAGE- BHUNDI, BLOCK- KHUDAGANJ, DISTT- SHAHAJANHAPUR
UNDER
JAL JIVAN MISSION

Introduction :

A Deep bore hole was drilled 120 mtrs. depth. and Logged depth 100 mtrs. at above site. Was drilled by M/S NCC Ltd., Shahajanhapur.

On the request of M/S NCC Ltd., Shahajanhapur. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 19.Nov.2021.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major equifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 10	5	Clay kankar	
3.	10 - 16	6	Sandy clay	
4.	16 - 20	4	Clay kankar	
5.	20 - 32	12	Medium sand	Good
6.	32 - 35	3	Clay kankar	
7.	35 - 37	2	Very fine sand	
8.	37 - 42	5	Clay kankar	
9.	42 - 53*	11	Medium sand	Good
10.	53 - 57	4	Clay kankar	
11.	57 - 60	3	Very fine sand	
12.	60 - 66	6	Clay kankar	
13.	66 - 92*	26	Medium sand	Good
14.	92 - 98	6	Clay kankar	
15.	98 - 100*	2	Medium sand	Good

Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting starta chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Good.
4. Expected discharge is 1000 to 1100 L.P.M.
5. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
6. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist

UTS
P.H.

Geophysicist

Ground Water Survey Consultancy

Legging VI Bhandi
 Block: Khudaganj
 Distt: Shahjahanpur
 LOGGIIIGUP
 19 Nov 2021
 19-40
 Lallesh sharma

Rho a
 NI6 (SN)
 NS4(LN)
 LAT

SP (mV)

