

GROUND WATER SURVEY CONSULTANCY  
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL  
ELECTOLOGGING REPORT

Ref No:-A- 324

Date:- 20-04-2023

NAME OF SITE

GRAM PANCHAYAT- Dari Bichola      BLOCK- Madnapur      DISTT- Shahjahanpur

NAME OF AGENCY

M/s NCC Ltd.  
Shahjahanpur



GROUND WATER SURVEY CONSULTANCY  
Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.  
112 A-Shrce Nagar Colony, Firozabad Road, Agra- 282006  
(M) : 9412260823, 9794625420, 9761163000, Email : gwsc\_agra@yahoo.com

**ISO ; 9001 : 2015**

Ground Water Survey Consultancy  
Agra

# REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- DARI BICHOLA, BLOCK- MADNAPUR,  
DISTT- SHAHJAHANPUR  
UNDER  
JAL JIVAN MISSION

## Introduction :

A Deep bore hole was drilled 120 mtrs. depth. and Logged depth 120 mtrs. at above site. Was drilled by M/S NCC Ltd., Shahjahanpur.

On the request of M/S NCC Ltd., Shahjahanpur. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 20:April.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 10	5	Fine to Medium sand	Med to Good
3.	10 - 20	10	Clay kankar	
4.	20 - 31	11	Medium sand	Med to Good
5.	31 - 34	3	Clay kankar	
6.	34 - 36	2	Fine to Medium sand	Med to Good
7.	36 - 41	5	Clay kankar	
8.	41 - 74*	33	Medium sand	Med to Good
9.	74 - 78	4	Clay kankar	
10.	78 - 83*	5	Fine to Medium sand	Med to Good
11.	83 - 85	2	Clay kankar	
12.	85 - 87	2	Fine sand	Med to Good
13.	87 - 94	7	Clay kankar	
14.	94 - 120*	26	Medium sand	Med to Good

**Conclusions and Recommendations :-**

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (\*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium to Good.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

**Geophysicist**



**Ground Water Survey Consultancy**

Run 1

NI 6 (SN)  
NS4(QN)  
LAT

Logging Details:

Start Date: 02/22/23  
End Date: 02/22/23  
Time: 10:00 AM  
Location: G-201-23

Logger: S. H. B.  
Log File: NSIS/S/02/22-23

SP (mV)

Logger Model: DMPL-2

Logger Connected by:  
GROUND WATER SURVEY CONSULTANCY  
AGRA, UP, INDIA

