

# GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

## GEO-PHYSICAL WELL ELECTROLOGGING REPORT

Ref No:-B-2173

Date:- 23-10-2023

### NAME OF SITE

GRAM PANCHAYAT- Totpur Khrsai      BLOCK- Dahagawan      DISTT- Badaun

### NAME OF AGENCY


M/s PNC-SPML-JV  
Badaun



**GROUND WATER SURVEY CONSULTANCY**  
Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.  
112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006  
(M) : 9412260823, 9794625420, 9761163000, Email : gwsc\_agra@yahoo.com

**ISO ; 9001 : 2015**

Ground Water Survey Consultancy



# REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- TOTPUR KHRSAL, BLOCK- DAHAGAWAN,  
DISTT- BADAUN  
UNDER  
JAL JIVAN MISSION

## Introduction :


A Deep bore hole was drilled 145 mtrs. depth. and Logged depth 142 mtrs. at above site. Was drilled by M/S PNC-SPML-JV, Badaun.

On the request of M/S PNC-SPML-JV, Badaun. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 23.Oct.2023.

Logging Parameters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 8	3	Clay kankar	
3.	8 - 12	4	Fine sand	
4.	12 - 16	4	Clay kankar	
5.	16 - 25	9	Medium sand	Medium
6.	25 - 38	13	Clay kankar	
7.	38 - 62*	24	Medium sand	Medium
8.	62 - 75	13	Clay kankar	
9.	75 - 80*	5	Fine to Medium sand	Medium
10.	80 - 97	17	Clay kankar	
11.	97 - 105*	8	Medium sand	Medium
12.	105 - 110	5	Clay kankar	
13.	110 - 118*	8	Fine to Medium sand	Medium
14.	118 - 142	24	Clay kankar	

Ground Water Survey Consultancy



## Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (\*) appear to be aquifer zones for possible Development of tube well.
3. The Quality of water is expected Medium.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist



Ground Water Survey Consultancy

Rhos a  
 N16 (SN)  
 N64(QUN)  
 LAT

Logging Details:  
 Log No: 30 T 0001 0118  
 Date: 23 Oct 2013  
 Log Loc: N64(QUN)  
 Log No: 23 Oct 2013  
 Lat: 16° 16'  
 Long: 75° 21'

Logger: S. H. K.  
 Log No: 21-22  
 Log Loc: N64(QUN)

B  
 SP (m V)  
 Logger Model: GMBL-2  
 Logger Owned by: GROUND WATER SURVEY CONSULTANCY Agra, UP, India

