

GROUND WATER SURVEY CONSULTANCY
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

**GEO-PHYSICAL WELL
ELECTROLOGGING REPORT**

Ref No:-B-502

Date:- 16-05-2023

NAME OF SITE

GRAM PANCHAYAT- Ladhera

BLOCK- Bisauli

DISTT- Badaun

NAME OF AGENCY

M/s PNC-SPML-JV
Badaun



GROUND WATER SURVEY CONSULTANCY
Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.
112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO ; 9001 : 2015

Ground Water Survey Consultancy

J. Aggarwal

REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- LADHERA, BLOCK- BISAULI, DISTT.- BADAUN
UNDER
JAL JIVAN MISSION

Introduction :

A Deep bore hole was drilled 110 mtrs. depth. and Logged depth 110 mtrs. at above site. Was drilled by M/S PNC-SPML-JV, Badaun.

On the request of M/S PNC-SPML-JV, Badaun. a Geophysical well Logging is conduct at above bore hole using IGIS Well Logger on 16.May.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 10	4	Clay kankar	
3.	10 - 20	10	Dry sand	
4.	20 - 25	5	Fine sand	
5.	25 - 34	9	Clay kankar	
6.	34 - 56	22	Medium sand	Good
7.	56 - 65	9	Clay kankar	
8.	65 - 80*	15	Medium sand	Good
9.	80 - 85	5	Kankar	
10.	85 - 100*	15	Medium sand	Good
11.	100 - 110	10	Clay kankar	


Ground Water Survey Consultancy

TC
Agra
6/21

Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Good.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist



Ground Water Survey Consultancy

Vill-Lachanda Block,
Bisauli Dist-
Badam, Vill-
Lachanda Block,
Bisauli Dist-Badam,
LOG/SH/04p
16 May 2003
13:03
Uttarish Gupta IGC

Rho s
N16 (SN)
MS4(LN)
LAT

SP (m V)

