

GROUND WATER SURVEY CONSULTANCY

GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL ELECTROLOGGING REPORT

Ref No:-A-2436

Date:- 26-12-2023

NAME OF SITE

Gram Panchayat- Kot

BLOCK- Bisauli

DISTT- Badaun

NAME OF AGENCY

M/s PNC-SPML-JV
Badaun



GROUND WATER SURVEY CONSULTANCY

Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.


112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO ; 9001 : 2015

Ground Water Survey Consultancy

Agra



REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- KOT, BLOCK- BISAULI, DISTT- BADAUN
UNDER
JAL JIVAN MISSION

Introduction :

A Deep bore hole was drilled 120 mtrs. depth. and Logged depth 116 mtrs. at above site. Was drilled by M/S PNC-SPML-JV, Badaun.

On the request of M/S PNC-SPML-JV, Badaun. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 26.Dec.2023.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major aquifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 20	15	Dry sand	
3.	20 - 35	15	Clay kankar	
4.	35 - 52*	17	Medium sand	Medium
5.	52 - 67	15	Clay kankar	
6.	67 - 82*	15	Medium sand	Medium
7.	82 - 86	4	Clay kankar	
8.	86 - 100*	14	Medium sand	Medium
9.	100 - 110	10	Clay kankar	
10.	110 - 114	4	Fine sand	Medium
11.	114 - 116	2	Clay kankar	


Ground Water Survey Consultancy



Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting strata chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium.
4. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
5. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geologist



Rhoo a
 NI6 (SN)
 NS4(LN)
 LAT
 Logging Details:
 Logging GP: Kori Block Bikaner
 Distt: Bikaner
 GP LOGGING: GP
 28 Dec 2013
 15.28
 Usharbh Gupta (AG)

Logger S/N: IGIS/S/04/21-22

Logger Model: SP (m V)
 DMAPL-2
 Logger Owned by:
 GROUND WATER SURVEY CONSULTANCY - AGRA, INDIA

