

GROUND WATER SURVEY CONSULTANCY  
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL  
ELECTROLOGGING REPORT

Ref No:- 537

Date:- 02-03-2022

NAME OF SITE

GRAM PANCHAYAT- Bhagwantapur      BLOCK- Banda      DISTT- Shahjanhapur

NAME OF AGENCY

M/s NCC Ltd.  
Shahjanhapur



GROUND WATER SURVEY CONSULTANCY  
Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.  
112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006  
(M) : 9412260823, 9794625420, 9761163000, Email : gwsc\_agra@yahoo.com

**ISO ; 9001 : 2015**

Ground Water Survey Consultancy



# REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- BHAGWANTAPUR, BLOCK- BANDA  
DISTT- SHAHJANHAPUR  
UNDER  
JAL JIVAN MISSION

## Introduction :

A Deep bore hole was drilled 143 mtrs. depth. and Logged depth 140 mtrs. at above site. Was drilled by M/S NCC Ltd., Shahajanhapur.

On the request of M/S NCC Ltd., Shahajanhapur. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 02.Mar.2022.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major equifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 15	10	Clay kankar	
3.	15 - 26	11	Fine to Medium sand	
4.	26 - 30	4	Clay kankar	
5.	30 - 40	10	Fine to Medium sand	Good
6.	40 - 45	5	Clay kankar	
7.	45 - 59*	14	Medium sand	Good
8.	59 - 61	2	Clay kankar	
9.	61 - 75*	14	Medium sand	Good
10.	75 - 80	5	Clay kankar	
11.	80 - 106*	26	Fine to Med. sand & Kankar	Good
12.	106 - 115	9	Clay kankar	
13.	115 - 135*	20	Medium sand	Good
14.	135 - 140	5	Clay kankar	

**Conclusions and Recommendations :-**

1. The Lithology broadly tallies with that of drill cutting starta chart.
2. The zones marked with asterisk (\*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Good.
4. Expected discharge is 1000 to 1100 L.P.M.
5. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
6. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

**Geophysicist**



**Ground Water Survey Consultancy**

Rho a  
 M16 (SN)  
 N64(L/N)  
 LAT

Logging GP  
 Bhagwanapur Block:  
 Banda Distt  
 Shahjahanpur  
 LOGGILGUP  
 02.11.2022  
 CC 36  
 Ulkarish Gupta (4G)

SP (m V)

