

GROUND WATER SURVEY CONSULTANCY
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL
ELECTROLOGGING REPORT

Ref No:- 680

Date:- 28-03-2022

NAME OF SITE

GRAM PANCHAYAT- Barnai BLOCK- Bhawal Khera DISTT- Shahjahanpur

NAME OF AGENCY


M/s NCC Ltd.
Shahjahanpur



GROUND WATER SURVEY CONSULTANCY
Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.
112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO ; 9001 : 2015

Ground Water Survey Consultancy



REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- BARNAI, BLOCK- BHAWAL KHERA
DISTT- SHAHJAHANPUR
UNDER
JAL JIVAN MISSION

Introduction :


A Deep bore hole was drilled 135 mtrs. depth. and Logged depth 130 mtrs. at above site. Was drilled by M/S NCC Ltd., Shahajanhapur.

On the request of M/S NCC Ltd., Shahajanhapur. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 28.Mar.2022.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major equifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-


S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 13	8	Clay kankar	
3.	13 - 30	17	Fine sand	
4.	30 - 36	6	Clay kankar	
5.	36 - 61*	25	Medium sand	Med. to Good
6.	61 - 75	14	Clay kankar	
7.	75 - 78	3	Fine sand	Med. to Good
8.	78 - 90	12	Clay kankar	
9.	90 - 102*	12	Medium sand	Med. to Good
10.	102 - 115	13	Clay kankar	
11.	115 - 125*	10	Fine to Medium sand	Med. to Good
12.	125 - 130	5	Clay kankar	

Ground Water Survey Consultancy



Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting starta chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Medium to Good.
4. Expected discharge is 800 to 900 L.P.M.
5. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
6. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.



Ground Water Survey Consultancy

Rho a
 NI6 (SN)
 NS4(LN)
 LAT

Logging VI Baral
 Block: Bhowal Kheta
 Distt: Shahjahanpur
 LOGGII/GUP
 28.1.18/2022
 15-21
 Uttamish Gupta (L/G)

SP (m V)

