

GROUND WATER SURVEY CONSULTANCY
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL
ELECTROLOGGING REPORT

Ref No:- 611

Date:- 10-03-2022

NAME OF SITE

GRAM PANCHAYAT- Bilsanda Bujurg
DISTT- Shahjanhapur

BLOCK- Puwayan

NAME OF AGENCY

M/s NCC Ltd.
Shahjanhapur



GROUND WATER SURVEY CONSULTANCY


Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.

112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006

(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO ; 9001 : 2015

Ground Water Survey Consultancy



REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- BILSANDA BUJURG, BLOCK- PUWAYAN
DISTT- SHAHJANHAPUR
UNDER
JAL JIVAN MISSION

Introduction :

A Deep bore hole was drilled 145 mtrs. depth. and Logged depth 143 mtrs. at above site. Was drilled by M/S NCC Ltd., Shahajanapur.

On the request of M/S NCC Ltd., Shahajanapur. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 10.Mar.2022.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major equifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 12	7	Fine sand	
3.	12 - 25	13	Clay kankar	
4.	25 - 38	13	Fine to Medium sand	Good
5.	38 - 53	15	Clay kankar	
6.	53 - 80*	27	Medium sand	Good
7.	80 - 90	10	Clay kankar	
8.	90 - 122*	32	Medium sand	Good
9.	122 - 125	3	Clay kankar	
10.	125 - 140*	15	Medium sand	Good
11.	140 - 143	3	Clay kankar	


Ground Water Survey Consultancy



Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting starta chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Good.
4. Expected discharge is 1000 to 1100 L.P.M.
5. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
6. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist



Ground Water Survey Consultancy

Plot 3
 NISSN
 N64 Q11
 LAT

Department of Geology
 University of Delhi
 Delhi-110007
 India
 Date: 12/12/2012
 Page No: 1/1
 Ref. No:

