

GROUND WATER SURVEY CONSULTANCY
GEOLOGISTS, GEOPHYSICISTS & TUBEWELL ENGINEERS

GEO-PHYSICAL WELL
ELECTOLOGGING REPORT

Ref No:- 434

Date:- 13-02-2022

NAME OF SITE

GRAM PANCHAYAT- Kamalpur BLOCK- Banda DISTT- Shahjanhapur

NAME OF AGENCY


M/s NCC Ltd.
Shahjanhapur



GROUND WATER SURVEY CONSULTANCY
Electric Well Logging, Geophysical Resistivity Survey, Ground Water Investigations.
112 A-Shree Nagar Colony, Firozabad Road, Agra- 282006
(M) : 9412260823, 9794625420, 9761163000, Email : gwsc_agra@yahoo.com

ISO ; 9001 : 2015

Ground Water Survey Consultancy



REPORT ON GEOPHYSICAL WELL LOGGING AT

GRAM PANCHAYAT- KAMALPUR, BLOCK- BANDA, DISTT- SHAHJANHAPUR
UNDER
JAL JIVAN MISSION

Introduction :

A Deep bore hole was drilled 131 mtrs. depth. and Logged depth 121 mtrs. at above site. Was drilled by M/S NCC Ltd., Shahajanhapur.

On the request of M/S NCC Ltd., Shahajanhapur. a Geophysical well Logging in the above bore hole using IGIS Well Logger on 13.Feb.2022.

Logging Para meters - Self potential, short normal (N-16), Long Normal (N-64), Lateral. Details of major equifer formations explored from logging of bore hole combined with the study of Strata Chart prepared from drill cuttings are given in the following table:-

S.No.	Depth range(m)	Thickness(m)	Lithology	Expected Water Quality
1.	0 - 5	5	Surface soil	
2.	5 - 10	5	Clay	
3.	10 - 25	15	Fine sand	
4.	25 - 30	5	Clay kankar	
5.	30 - 42	12	Medium sand	Good
6.	42 - 65	23	Clay kankar	
7.	65 - 77*	12	Meduim sand	Good
8.	77 - 83	6	Clay kankar	
9.	83 - 87	4	Fine sand	Good
10.	87 - 96	9	Clay kankar	
11.	96 - 102*	6	Fine to Medium sand	Good
12.	102 - 105	3	Clay kankar	
13.	105 - 121*	16	Medium sand	Good

Conclusions and Recommendations :-

1. The Lithology broadly tallies with that of drill cutting starta chart.
2. The zones marked with asterisk (*) appear to be aquifer zones for possible development of tubewell.
3. The Quality of water is expected Good.
4. Expected discharge is 600 to 700 L.P.M.
5. It is recommended to have a chemical and bacteriological analysis of the water sample before using it for human consumption or for any other use.
6. All projections and recommendations are subject to the inherent limitations of the technique employed and there could be variations as the underground conditions are not always amenable to physical interpretations.

Geophysicist



Ground Water Survey Consultancy

Rhe a

- ▬ NISSN
- ▬ N64 (UN)
- ▬ LAT

LOCATION:
 1. LOCATION
 2. LOCATION
 3. LOCATION
 4. LOCATION
 5. LOCATION
 6. LOCATION
 7. LOCATION
 8. LOCATION
 9. LOCATION
 10. LOCATION
 11. LOCATION
 12. LOCATION
 13. LOCATION
 14. LOCATION
 15. LOCATION
 16. LOCATION
 17. LOCATION
 18. LOCATION
 19. LOCATION
 20. LOCATION

SP

